

UNOFFICIAL



200307220130
Skagit County Auditor

7/22/2003 Page 1 of 1 3:34PM

DRINKING WATER SYSTEM STATUS REPORT

I, the undersigned property owner, in making an application for a building permit involving a single-family residence acknowledge that this notice is being signed, notarized and recorded in compliance with Skagit County Code Section 12.48.270 in regards to the drinking water source which is an alternative source other than a drilled well requiring filtration and disinfection treatment.

1. I agree to record this notice with the Skagit County Auditor's Office for the purpose of it being made a part of the record of title.
2. I understand that this notice will appear on any title search or record search, and we have no objection nor will we make claims against Skagit County as a consequence of this recording.
3. This residence is served dug well that is eighteen feet deep with a twelve feet seal. The Wash. State Dept. of Ecology issued a variance on May 16, 2002 to allow the shorter seal instead of an eighteen foot seal. The source requires properly maintained filtration and disinfection equipment for consistent and potable water. Filtration and disinfection are provided by the following system: one-1-micron-bag filter, an ultraviolet disinfection unit, an 6 gpm flow restrictor, and two-.5 micron-carbon block filters. Poor water clarity (turbidity) may indicate that pathogens may be present at times in the drinking water. The Health Officer recommends that property owners exercise caution in the use of this drinking water system by:
 - a. conserving water use by installing low water use landscaping and fixtures,
 - b. having spare ultraviolet light bulbs, cartridge filters and maintaining a operation and maintenance log,
 - c. testing for turbidity during times of poor water clarity,
 - d. testing for bacteria on a quarterly basis and
 - e. providing appropriate maintenance to the filtration and disinfection units as directed by the manufacturer.
4. **Properites with water systems with filed status reports will not be used as justification for the creation of new lots and cannot be further subdivided.**
5. Specific drinking water system information for this lot may be on file at the Skagit County Department of Health.

24-36-3

OWNER: CRIS L. FERINGER SITE ADDRESS: 3054 LILY LAKE RD., BOW, WA, 98232
P#48777 ASSESSOR'S ACCT: 3603242-005-0008

OWNER (signature) Cris L. Feringer Cris L. Feringer

Subscribed and sworn to me this 22nd day of July

Notary Public in and for the State of Washington.
Melody R. Devossett Residing at Burlington

