



200706060117  
Skagit County Auditor

6/6/2007 Page 1 of 1 11:00AM

SEAWATER INTRUSION DRINKING WATER STATUS REPORT

I, the undersigned property owner, in making an application for a building permit involving a single-family residence, acknowledge that this notice is being signed, notarized and recorded in compliance with Skagit County (S.C.) Resolution #15570 signed December 12, 1994. This parcel is located in a **Seawater Intrusion Area**. The owners of this parcel must follow Interim Resolution #15570 or its successor.

1. I agree to record this notice with the Skagit County Auditor's Office for the purpose of it being made a part of the record of title.
2. I understand that this notice will appear on any title search or record search, and we have no objection nor will we make claims against Skagit County as a consequence of this recording.
3. The drinking water source for this single-family residence (P78306) is a 135-foot well drilled May 15, 2007. The well is located less than 1/2 mile from the coastline. According to the owners, the well was drilled as far inland as possible. The owners showed documentation that the pump is limited to 5 gpm and a wellhead source meter will be installed prior to building permit final.
4. The 5/17/2007 well sample measured 72 ppm chlorides and 64.4 ppm sodium. The State Maximum Contaminant Level (MCL) for Chloride is 250 ppm. Home water softeners that add additional sodium to the water are not recommended for this water. Resolution #15570 requires the property owner to:
  - a. utilize a maximum pumping rate of 5 gallons per minute or less,
  - b. record the static water levels quarterly the first year and annually in September thereafter,
  - c. record the chloride test results, prior to treatment if treated, in September annually,
  - d. record the well head meter readings monthly for the first year of residence and annually thereafter, and use all reasonable water conservation measures.

These records will be submitted to the Skagit County Health Department. This data will be used for educational purposes only and not for enforcement action.

5. Land division proposals with chloride test results of 200 or greater ppm will be denied.
6. Specific drinking water system information for this lot may be on file at the Skagit County Auditors Office or Planning and Development Services

LEGAL DESCRIPTION: Replat of Assessors Plat Ashlund ADD TR3

SITE ADDRESS: 16181 Snee0oosh Road

ASSESSOR'S ACCOUNT NO: 4212-000-003-0003

OWNER (PRINT NAME): Patrick and Jennifer Gudmundson

MAILING ADDRESS: 224 Garden of Eden Road , Sedro Woolley , WA 98284

OWNER (SIGNATURE): *Jennifer R. Gudmundson*

Subscribed and sworn to me this 6<sup>TH</sup> day of JUNE  
Notary Public in and for the State of Washington.

*Patti J. Chambers* Residing at Mount Vernon

