



201307190160

Skagit County Auditor

\$72.00

7/19/2013 Page

1 of

1 4:27PM

SEAWATER INTRUSION DRINKING WATER STATUS REPORT

I, the undersigned property owner, in making an application for a building permit involving a single-family residence, acknowledge that this notice is being signed, notarized and recorded in compliance with Skagit County (S.C.) Resolution #15570 signed December 12, 1994. This parcel is located in a **Seawater Intrusion Area**. The owners of this parcel must follow Interim Resolution #15570 or its successor.

1. I agree to record this notice with the Skagit County Auditor's Office for the purpose of it being made a part of the record of title.
2. I understand that this notice will appear on any title search or record search, and we have no objection nor will we make claims against Skagit County as a consequence of this recording.
3. The drinking water source for this single-family residence is a 97'-foot deep drilled well. The well is located less than 1/2 mile from the coastline. The owners showed documentation that a 5 gpm pump restrictor and sounding tube were installed.
4. The June 18, 2013 well sample measured 53 ppm chlorides and 462  $\mu$ s conductivity. Home water softeners that add additional sodium to the water are not recommended for this water. Resolution #15570 and Skagit County Hydrogeology review require the property owner to:
  - a. utilize a maximum pumping rate of 5 gallon per minute or less,
  - b. record the static water levels annually in September,
  - c. record the chloride test results, prior to treatment if any, in September annually, and
  - d. all reasonable water conservation measures shall be utilized for well (BBS 769).
 These records shall be submitted to the Skagit County Health Department. This data will be used for educational purposes only and not for enforcement action.
5. Specific drinking water system information for this lot may be on file at the Skagit County Department of Health or Permit Center. (WA13-0022)

LEGAL DESCRIPTION: P# 112635 Lt 4 SP 97-032  
 SITE ADDRESS: 6642 West Shore Drive, Anacortes WA 98221  
 ASSESSOR'S ACCOUNT NO: 350102-0-007-0300  
 OWNER (PRINT NAME): Robert and William Bloxom  
 MAILING ADDRESS: F.C. Bloxom Company, 2250 Occidental Ave, Seattle WA 98134  
 OWNER (SIGNATURE): [Signature]

Subscribed and sworn to me this 24<sup>th</sup> day of June, 20 13  
 Notary Public in and for the State of Washington.

Catherine Adams Residing at Seattle Wa 98112

