



201601150072


DRINKING WATER QUALITY SYSTEM REPORT

I, the undersigned property owner, in making an application for a building permit involving a single-family residence acknowledge that this notice is being signed, notarized and recorded in compliance with Skagit County Code Section 12.48.270 in regards to a drinking water quality parameter that exceeds the maximum contaminant level but is treatable to below the maximum contaminant level.

1. I agree to record this notice with the Skagit County Auditor's Office for the purpose of it being made a part of the record of title.
2. I understand that this notice will appear on any title search or record search, and we have no objection nor will we make claims against Skagit County as a consequence of this recording.
3. The drinking water source for this individual residential is from dug well (DOE TAG # BHK 426) which is located in an area exhibiting nitrates in the aquifer. The inorganic chemistry taken on September 11, 2015 had high levels of Nitrates. The nitrate level was 16.5 mg/l which is above the EPA Maximum Contaminant Level of 10 mg/l. The drinking water well on P32635 is vulnerable due to its shallow source. The post treatment Nitrate inorganic chemistry result taken on 1/08/2016 had a nitrate level of 0.38 mg/L. **Treatment is provided by a Purolite A-520E filter using ion exchange resin to remove the nitrates followed by a PURA UV30 Ultraviolet light to remove bacteria.** The Health Officer recommends that property owners exercise caution in the use of this drinking water system by:
 - a. This property may not be subdivided unless PUD#1or Anacortes City water is available to all lots,
 - b. The building permit for the residence on P#32635 is conditioned upon treatment being provided for the water source that will lower the Nitrates below 10 mg/L,
 - c. The property owner will need to sample and maintain the treatment system to avoid adverse health effects as any untreated water is considered unsafe for consumption, and
 - d. The property owner shall abandon this water source as a source of potable water per WAC 173-160 and connect to PUD #1or Anacortes Public Water when it becomes available.
4. Water systems with filed status reports will not be used for the creation of new lots unless Public Water is provided.
5. Specific drinking water system information for this lot is on file at the Skagit County Planning and Permit Center. (WA15-0085)

SITE ADDRESS: 11046 "O" Avenue, Anacortes, WA 98221
 PARCEL NUMBER: P# 32635
 ASSESSOR'S ACCOUNT NO: 350136-1-003-0001
 OWNER: Welk, David & Macy
 MAILING ADDRESS: 11046 "O" Avenue, Anacortes, WA 98221
 OWNER (SIGNATURE): David & Macy Welk

36135/01 NENE



Subscribed and sworn before me this 15th day of Jan, 2016
Notary Public in and for the State of Washington.

Cindy Gauthier Residing at Skagit County WA 7/23/2019