

Exhibit 11-3

Existing and Proposed Interties			
Intertie	Existing ¹	Proposed	Function ²
1. Anacortes – Oak Harbor and US Navy	X		Base
2. Anacortes – LaConner/ Shelter Bay/ Swinomish Reservation	X		Base and Emergency (Swinomish)
3. Anacortes – Skagit PUD			
a) Fidalgo Island (4 each)	X		Base
b) Fredonia	X		Base
c) Memorial Highway	X		Base
d) Avon	X		Base
e) Riverbend	X		Seasonal/Peak
4. Anacortes – Del Mar Community	X		Seasonal/Peak
5. Skagit PUD – Blanchard Edison	X		Emergency
6. Skagit PUD – Samish Farms	X		Base

Footnotes:

¹ Except for the Anacortes – Skagit PUD Riverbend facility, all interties were in existence on January 1, 1991.

² The function of the interties are categorized as follows for the purposes of this CWSP:

- Emergency – The connecting valve is closed except during short-term periods when water shortages exist due to emergency conditions.
- Seasonal/peak – The intertie is routinely used on an annual basis, normally during the summer, peak use period.
- Base – The intertie provides the base supply to a utility as a wholesale customer.
- Conjunctive – Two or more sources of water are utilized by the intertied utilities to improve overall system reliability, optimize system operations, and/or achieve the most efficient use of the combined resources.