



DESIGN SPEED (MPH)	Not applicable
MAXIMUM ROAD GRADE (Percent)	12% unpaved, 14% paved
MINIMUM ROAD GRADE (Percent)	0.5% recommended
MINIMUM ROADWAY WIDTH (Ft)	12
MINIMUM SURFACING WIDTH (Ft)	12
MINIMUM DESIGN LOAD	HS 20-44 (bridges)
MINIMUM EASEMENT WIDTH (Ft)	20 off of owner's property
MINIMUM REQUIRED SURFACING:	
CRUSHED SURFACING TOP COURSE	2" compacted depth recommended
GRAVEL BASE	8" compacted depth recommended
VERTICAL CLEARANCE	13.5 ft.

NOTES:

1. A 20' minimum easement must be secured for driveways crossing other landowner's properties.
2. Turnouts are required for driveways in excess of 300 feet in length. Turnouts shall be a portion of the road that is widened to a 20' driving surface for a length of 30' and tapered back into the driveway at a 45-degree angle.
3. All turns shall have an outside turning radius of 50'.

Driveway.doc



SKAGIT COUNTY
DEPARTMENT OF
PUBLIC WORKS

REVISIONS	DATE

**ROADWAY
STANDARDS**

**DRIVEWAY
(Over 150 feet in length)
FIGURE C - 18**

6/26/2000