



**Guemes Island Ferry Replacement
Electrical Power Load Analysis**

PREPARED FOR: Skagit County Mt Vernon, Washington			BY: JMG	
 1201 WESTERN AVENUE, SUITE 200 SEATTLE, WASHINGTON 98101-2953 T 206.624.7850 GLOSTEN.COM			CHECKED: JMR	
DOCUMENT:	REVISION:	FILE:	APPROVED: MSM	
17097.02-300-01	P0	17097.02	DATE: 23-Sep-2020	

SUMMARY

- The purpose of this electrical load analysis is to evaluate the total electric plant loads associated with several different operations of the replacement ferry concept.
- The primary source of energy for the vessel under normal operations is shore-side electrical power. Battery banks are charged once per round trip. Stored energy is then distributed via inverters to propulsion motors and ship service loads while the ferry operates.
- The "No Charging" load case represents contingency operations using only the Auxiliary generator, including powering the shoreside ramps from the vessel. This shows the minimum available propulsion power in the event that shore charging is unavailable. Additional power would be available from the batteries, with extra dock time required to recharge the batteries between trips.
- The "Emergency" load case shows the ship service loading associated with setting all demand factors to 1. This demonstrates the emergency ability to supply all connected loads simultaneously, as would be required by 46 CFR 112.05-5(a) for vessels inspected under other subchapters
- This electric plant is designed to meet the requirements of 46 CFR § 183. In particular, all loads specified by §183.310 (a) (1) can be powered by either of the two battery banks via two separate DC/AC inverters.
- In consideration of the small number of loads and limited crewing, ship service inverters are sized for the total "utilized load," rather than considering demand factors and sizing for the limiting load scenario.
- This load analysis includes margins for design uncertainty and a service life allowance to accommodate future growth.
- The summer and winter load cases are similar using current HVAC load estimates. Both cases are presented in this load analysis.
- Shore power is available at 480V and 60 amps. The load analysis indicates that the electrical demand does not exceed the available power.

GENERAL NOTES

- This document has been developed from information in References 1-4.
- Definitions and acronyms
 DF: Demand Factor, defined as the fraction of time that the load is operational in an operational profile.
 ekW: Electrical kilowatts
 FLA: Full Load Amperes
 HP: Horsepower
 kVA: Kilo Volt-Amperes
 UF: Utilization Factor, the fraction of the connected load rating that is utilized during normal operation.
 V: Voltage
 Φ: Number of phases
- Calculation procedure: Profile Load = Connected x Utilization Factor x Demand Factor / Efficiency*
 *Efficiency only included when circuit load is supplied through power conversion equipment
- DC bus and propulsion motor voltages are TBD.

REFERENCES

- GLOSTEN, 17097.02-300-02, VESSEL ELECTRICAL ONE LINE
- GLOSTEN, 17097.02, REQUEST FOR INFORMATION - VESSEL ELECTRICAL SYSTEM
- GLOSTEN, 17097.02, REQUEST FOR INFORMATION - SHORE ELECTRICAL SYSTEM
- GLOSTEN, 17097.02, REQUEST FOR INFORMATION - AUTOMATIC SHORE CONNECTION SYSTEM

REVISIONS SUMMARY

REV.	DESCRIPTION	DATE	APPROVED
P0	Initial Release		

Guemes Island Ferry Replacement Electrical Power Load Analysis	FILE:	17097.02	BY:	JMG
	REVISION:	P0	CHECKED:	JMR
	DATE:	9/23/2020	APPROVED:	MSM
	DOCUMENT:	17097.02-300-01		

PANEL:	1H (#1 Main DC SWBD)
LOCATION:	Switchboard Room

LOAD DATA														LOAD DATA INFORMATION			LOAD PROFILES														
Circuit No. or SWBS	Load Description	V	Φ	HP	FLA	Power Factor	Connected		UF	Eff.	Utilized		Load Notes	Rev.	Load Confidence	Load Data Source	Transit - Summer			Transit - Winter			Shore Power (Moored)			No Charging			Emergency		
							ekW	kVA			ekW	kVA					DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA
1H-1	3S (480VAC Aux Panel)	480	3		240	0.84	167	200		97%	118	141	Via inverter & 690/480 transformer					19	22		18	20	9	10		89	110		40	46	
1H-2	#1 Propulsion Motor Drive	690	3		628	1.	750	750	0.93	98.5%	708	708	Assumes end #1 aft, 80% case, 70/30 propulsion split			RFI	1.	708	708	1	708	708	0	0	0	0.4	283	283	1.0	708	708
	Propulsion design margin										7	7						7	7		7	7									
	Propulsion service life allowance										0	0																			
	Auxiliary design margin										12	12						12	12		12	12		12	12		12	12			
	Auxiliary service life allowance										6	6						6	6		6	6		6	6		6	6			
Totals							917	950			851	874						752	754		751	753		26	28		390	411		748	754

POWER SOURCES	PF	ekW	kVA
Battery Bank #1	1	800	800
Battery Bank #2	1	800	800
Aux Generator	0.8	565	706
Total Ship Power		2165	2306

MARGINS	Design	Service Life	Total Margin (kw)
Propulsion Power	1%	0%	10
Auxiliaries	10%	5%	27

POWER SOURCE LOADING	ekW	kVA	Configuration	Transit - Summer	Transit - Winter	Shore Power (Moored)	No Charging	Emergency
Normal Operations - Split Bus								
Battery Bank #1		800	800	94%	94%			94%
Battery Bank #2		800	800	40%	40%			46%
Backup Operations - one bank offline								
Battery Bank + Aux Generator		1365	1506.25	78%	79%			81%
Backup Operations - shore charging unavailable								
Aux Generator		565	706.25				93%	
				Total propulsion power limited to 405kw without discharging battery.				

SHORE POWER	ekW	kVA	Configuration	Transit - Summer	Transit - Winter	Shore Power (Moored)	No Charging	Emergency
Input Capacity		288	288	Based on 60A/480VAC		15%		

Ship Service Inverter Sizing	ekW	kVA	Configuration	Transit - Summer	Transit - Winter	Shore Power (Moored)	No Charging	Emergency
3S		120	140	Based on utilized portion of connected load			76%	32%
2S		70	70	Based on utilized portion of connected load			29%	58%

Guemes Island Ferry Replacement Electrical Power Load Analysis	FILE:	17097.02	BY:	JMG
	REVISION:	P0	CHECKED:	JMR
	DATE:	9/23/2020	APPROVED:	MSM
	DOCUMENT:	17097.02-300-01		

PANEL:	2H (#1 Main DC SWBD)
LOCATION:	Switchboard Room

Circuit No. or SWBS	Load Description	LOAD DATA										LOAD DATA INFORMATION			LOAD PROFILES																
		V	Φ	HP	FLA	Power Factor	Connected		UF	Eff.	Utilized		Load Notes	Rev.	Load Confidence	Load Data Source	Transit - Summer			Transit - Winter			Shore Power (Moored)			No Charging			Emergency		
							ekW	kVA			ekW	kVA					DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA
2H-1	2S (#2 208VAC Swbd)	208	3		324	1	100	107		97%	65	71	Via inverter & 690/208 transformer					11	13		17	18		15	16	1.	11	13		56	61
2H-2	#1 Propulsion Motor Drive	690	3		628	1	750	750	0.4	98.5%	305	305	Assumes end #1 aft, 80% case, 70/30 propulsion split			RFI	1.	305	305	1.	305	305	0.	0	0	0.4	122	122	1.0	305	305
	Propulsion design margin										3																				
	Propulsion service life allowance										0																				
	Auxiliary design margin										6																				
	Auxiliary service life allowance										3																				
	Totals						850	857			382	375						315	317		322	323		15	16		133	134		360	366

Guemes Island Ferry Replacement Electrical Power Load Analysis	FILE:	17097.02	BY:	JMG
	REVISION:	P0	CHECKED:	JMR
	DATE:	9/23/2020	APPROVED:	MSM
	DOCUMENT:	17097.02-300-01		

PANEL:	3S (480VAC Aux Panel)	FED FROM:	1H-1
LOCATION:	Switchboard Room	FEEDER CABLE:	(2)3C-3/0

Circuit No.	Load Description	LOAD DATA											LOAD DATA INFORMATION			LOAD PROFILES																							
		V	Φ	HP	FLA	Power Factor	Connected		UF	Eff.	Utilized		Load Notes	Rev.	Load Confidence	Load Data Source	Transit - Summer			Transit - Winter			Shore Power (Moored)			No Charging			Emergency										
		ekW	kVA	ekW	kVA	DF	ekW	kVA			DF	ekW					kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA										
3S-1	Feeder Disconnect (Inverter/Transformer)	480	3		241	1	200	200			-	-	-	-	Sized for utilized load plus spares		1	This Sheet																					
3S-2	1S (#1 208VAC Swbd)	480	3		87	1	65	73		0.97	46	51					(N/A)	(N/A)		18	21		17	20		8	10		18	21		36	42						
3S-3	Shore Power	480	3		60	1	40	50	0.		-	-					3	EPLA																					
3S-4	Aux Ramp Power (End 1)	480	3		50	1	33	42	1.		33	42	RFI				2	RFI										1.	33	42									
3S-5	Aux Ramp Power (End 1)	480	3		50	1	33	42	1.		33	42	RFI				2	RFI										1.	33	42									
3S-6	Generator Combustion Supply Blower (510-01)	480	3	1.9	3	0.8	1.9	2.4	1.		1.9	2.4					3	HVAC Dwg										1.	2	2	1.	2	2						
3S-7	Spare	480	3		25	1	17	21																															
3S-8	Spare	480	3		25	1	17	21																															
Totals							167	200			114	137								18	21		17	20		8	10		87	107		38	45						

Guemes Island Ferry Replacement Electrical Power Load Analysis	FILE:	17097.02	BY:	JMG
	REVISION:	P0	CHECKED:	JMR
	DATE:	9/23/2020	APPROVED:	MSM
	DOCUMENT:	17097.02-300-01		

PANEL:	2S (#2 208VAC Swbd)	FED FROM:	2H-1
LOCATION:	Switchboard Room	FEEDER CABLE:	(2)3C-4/0

LOAD DATA														LOAD DATA INFORMATION			LOAD PROFILES																	
Circuit No.	Load Description	V	φ	HP	FLA	Power Factor	Connected		UF	Eff.	Utilized		Load Notes	Rev.	Load Confidence	Load Data Source	Transit - Summer			Transit - Winter			Shore Power (Moored)			No Charging			Emergency					
							ekW	kVA			ekW	kVA					DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA			
2S-1	Feeder Disconnect (Inverter/Transformer)	208	3		291.5	1.	105	105			-	-			(N/A)	This Sheet																		
2S-2	Fire Pump	208	3	5	16.7	0.8	4.8	6.0	1.		4.8	6.0			3	Eq List	0.	0.	0.	0.	0.	0.	0.1	0.5	0.6	0.	0.	0.	0.	1.	4.8	6.		
2S-3	P2 - Hold Dk 208-120 Panel	208	3		59.6	0.99	21.3	21.5			11.3	10.0				N/A		1.5	1.6		5.	5.		6.5	6.6		1.5	1.6		9.6	9.8			
2S-4	P4 - Main Dk 208-120 Panel	208	3		62.6	1.	22.5	22.5			11.4	11.4				N/A			1.2	1.2		5.8	5.8		6.7	6.7		1.2	1.2		11.4	11.4		
2S-5	#2 Freshwater Pump	208	3	2.5	7.5	0.8	2.2	2.7	1.		2.2	2.7	Standby		1	Same as 1S	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	1.	2.2	2.7			
2S-6	#2 Thruster Steering Motor (Primary)	208	3		24.3	0.8	7.0	8.8	1.		7.0	8.8			3	Veth Proposal	0.2	1.4	1.8	0.2	1.4	1.8	0.	0.	0.	0.2	1.4	1.8	1.	7.	8.8			
2S-7	#2 Thruster Steering Motor (Backup)	208	3		24.3	0.8	7.0	8.8	1.		7.0	8.8			3	Veth Proposal	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.		
2S-8	#2 Thruster Lube Oil Pump	208	3		3.5	0.8	1.0	1.3	1.		1.0	1.3			3	Veth Proposal	1.	1.	1.3	1.	1.	1.3	0.	0.	0.	1.	1.	1.3	1.	1.	1.	1.3		
2S-9	#2 Thruster Lube Oil Filter/Separator	208	1		1.1	0.8	0.2	0.2	1.		0.2	0.2			3	CJC Datasheet	1.	0.2	0.2	1.	0.2	0.2	0.	0.	0.	1.	0.2	0.2	1.	0.2	0.2			
2S-10	Battery Room 2 AC	208	1		30.0	0.8	5.0	6.3	1.		5.0	6.3			1	See notes	0.8	4.	5.	0.4	2.	2.5	0.2	1.	1.3	0.8	4.	5.	1.	5.	6.3			
2S-11	Potable Water Pump	208	1	0.75	7.6	0.8	1.3	1.6	0.7		0.9	1.1			3	533 Dwg	0.1	0.1	0.1	0.1	0.1	0.1	0.	0.	0.	0.1	0.1	0.1	1.	0.9	1.1			
2S-12	Hot Water Heater	208	1		58	1.	12.	12.	1.		12.0	12.0			1	533 Dwg	0.1	1.2	1.2	0.1	1.2	1.2	0.	0.	0.	0.1	1.2	1.2	1.	12.	12.			
2S-13	Spare	208	1		15.	1.	3.1	3.1			0.00	0.00																						
2S-14	Spare	208	1		15.	1.	3.1	3.1			0.00	0.00																						
2S-15	Spare	208	1		15.	1.	3.1	3.1			0.00	0.00																						
2S-16	Spare	208	1		15.	1.	3.1	3.1			0.00	0.00																						
Totals							97	104			63	68						11	12		17	18		15	15		11	12		54	59			

Guemes Island Ferry Replacement Electrical Power Load Analysis	FILE:	17097.02	BY:	JMG
	REVISION:	P0	CHECKED:	JMR
	DATE:	9/23/2020	APPROVED:	MSM
	DOCUMENT:	17097.02-300-01		

PANEL:	P1 - Up. Dk 208-120 Panel	FED FROM:	1S-4
LOCATION:	Upper Deck Electrical Room	FEEDER CABLE:	3C-1 AWG

Circuit No.	Load Description	V	Φ	HP	FLA	Power Factor	Connected		UF	Eff.	Utilized		Load Notes	Rev.	Load Confidence	Load Data Source	LOAD PROFILES													
							ekW	kVA			Transit - Summer						Transit - Winter			Shore Power (Moored)			No Charging			Emergency				
											DF	ekW					kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	
P1-1	Pilot House Heater (510-13)	208	1		11.1	1.	2.3	2.3	1.		2.3	2.3		3	HVAC Dwg	0.	0.	0.	0.5	1.2	1.2	0.7	1.6	1.6	0.	0.	0.	1.	2.3	2.3
P1-2	Crew Lounge Heater (510-13)	208	1		11.1	1.	2.3	2.3	1.		2.3	2.3		3	HVAC Dwg	0.	0.	0.	0.5	1.2	1.2	0.7	1.6	1.6	0.	0.	0.	1.	2.3	2.3
P1-3	Pilothouse lights	120	1		2.	1.	0.2	0.2	1.		0.2	0.2		1	Estimate	1.	0.24	0.2	1.	0.2	0.2	0.3	0.1	0.1	1.	0.2	0.2	1.	0.2	0.2
P1-4	Upper deck interior lights	120	1		2.	1.	0.2	0.2	1.		0.2	0.2		1	Estimate	1.	0.24	0.2	1.	0.2	0.2	0.3	0.1	0.1	1.	0.2	0.2	1.	0.2	0.2
P1-5	Main deck interior lights	120	1		2.	1.	0.2	0.2	1.		0.2	0.2		1	Estimate	1.	0.24	0.2	1.	0.2	0.2	0.3	0.1	0.1	1.	0.2	0.2	1.	0.2	0.2
P1-6	Exterior flood lights	120	1		10.	1.	1.2	1.2	1.		1.2	1.2		1	Estimate	1.	1.2	1.2	1.	1.2	1.2	0.3	0.4	0.4	1.	1.2	1.2	1.	1.2	1.2
P1-7	Navigation lights	120	1		2.	1.	0.2	0.2	1.		0.2	0.2		1	Estimate	1.	0.2	0.2	1.	0.2	0.2	0.3	0.1	0.1	1.	0.2	0.2	1.	0.2	0.2
P1-8	Pilothouse window wipers	120	1	0.5	9.8	0.8	0.9	1.1	1.		0.9	1.1		1	Estimate	1.	0.9	1.1	1.	0.9	1.1	0.1	0.1	0.1	1.	0.9	1.1	1.	0.9	1.1
P1-9	Searchlight	120	1		4.2	0.8	0.4	0.5	1.		0.4	0.5		1	Estimate	1.	0.4	0.5	1.	0.4	0.5	0.1	0.	0.1	1.	0.4	0.5	1.	0.4	0.5
P1-10	Depth Sounder	120	1		2.	1.	0.2	0.2	1.		0.2	0.2		1	Estimate	1.	0.2	0.2	1.	0.2	0.2	0.1	0.	0.	1.	0.2	0.2	1.	0.2	0.2
P1-11	Pilothouse Receptacles	120	1		30.	1.	3.6	3.6	0.2		0.7	0.7		1	Estimate	0.3	0.2	0.2	0.3	0.2	0.2	0.	0.	0.	0.3	0.2	0.2	1.	0.7	0.7
P1-12	Upper Deck Crew Lounge Receptacles	120	1		30.	1.	3.6	3.6	0.2		0.7	0.7		1	Estimate	0.3	0.2	0.2	0.3	0.2	0.2	0.	0.	0.	0.3	0.2	0.2	1.	0.7	0.7
P1-13	Crew Lounge Glove Dryer	120	1		5.	1.	0.6	0.6	1.		0.6	0.6		1	Estimate	0.	0.	0.	0.5	0.3	0.3	0.2	0.1	0.1	0.	0.	0.	1.	0.6	0.6
P1-14	Coffee Maker	120	1		1.	1.	0.1	0.1	1.		0.1	0.1		1	Estimate	1.	0.1	0.1	1.	0.1	0.1	0.1	0.	0.	1.	0.1	0.1	1.	0.1	0.1
P1-15	Pilothouse Electronics Supply Fan	120	1	0.25	5.8	0.8	0.5	0.7	1.		0.5	0.7		1	Estimate	1.	0.5	0.7	1.	0.5	0.7	1.	0.5	0.7	1.	0.5	0.7	1.	0.5	0.7
P1-16	Pilothouse 24VDC System/UPS	120	1		22.7	1.	2.7	2.7		0.95	2.9	1.0			N/A		1.2	1.2		1.2	1.2		0.7	0.7		1.2	1.2		1.2	1.2
P1-17	Pilothouse AC/Heater Unit (510-11)	120	1		15.3	1.	1.8	1.8	1.		1.84	1.84	Dual Modes	3	HVAC Dwg	0.8	1.5	1.5	0.8	1.5	1.5	0.2	0.4	0.4	0.8	1.5	1.5	1.	1.8	1.8
P1-18	Upper Deck Exhaust Fan (510-03)	120	1		0.7	0.8	0.1	0.1	1.		0.1	0.1		1	HVAC Dwg	1.	0.1	0.1	1.	0.1	0.1	1.	0.1	0.1	1.	0.1	0.1	1.	0.1	0.1
P1-19	Pilothouse window defroster (510-12)	120	1		15.4	1.	1.8	1.8	1.		1.85	1.85		3	HVAC Dwg	0.1	0.2	0.2	0.3	0.6	0.6	0.	0.	0.	0.8	1.5	1.5	1.	1.8	1.8
P1-20	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																		
P1-21	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																		
P1-22	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																		
P1-23	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																		
P1-24	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																		
Totals							28	28			13	12					8	8		8	9		3	3		9	9		11	12

Guemes Island Ferry Replacement Electrical Power Load Analysis	FILE:	17097.02	BY:	JMG
	REVISION:	P0	CHECKED:	JMR
	DATE:	9/23/2020	APPROVED:	MSM
	DOCUMENT:	17097.02-300-01		

PANEL:	P2 - Hold Dk 208-120 Panel	FED FROM:	2S-5
LOCATION:	Switchboard Room	FEEDER CABLE:	3C-14 AWG

Circuit No.	Load Description	V	Φ	HP	FLA	Power Factor	Connected		UF	Eff.	Utilized		Load Notes	Rev.	Load Confidence	Load Data Source	LOAD PROFILES													
							ekW	kVA			Transit - Summer						Transit - Winter			Shore Power (Moored)			No Charging			Emergency				
											DF	ekW					kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	
P2-1	Battery Room 2 Heater (510-13)	208	1		11.1	1.	2.3	2.3	1.		2.3	2.3		3	HVAC Dwg	0.	0.	0.	0.5	1.2	1.2	0.7	1.6	1.6	0.	0.	0.	1.	2.3	2.3
P2-2	Generator Room Heater (510-13)	208	1		11.1	1.	2.3	2.3	1.		2.3	2.3		3	HVAC Dwg	0.	0.	0.	0.5	1.2	1.2	0.7	1.6	1.6	0.	0.	0.	1.	2.3	2.3
P2-3	Switchboard Room Heater (510-13)	208	1		11.1	1.	2.3	2.3	1.		2.3	2.3		3	HVAC Dwg	0.	0.	0.	0.5	1.2	1.2	0.7	1.6	1.6	0.	0.	0.	1.	2.3	2.3
P2-4	End 1 Propulsion Motor Space Heater	208	1		1.	1.	0.2	0.2	1.		0.2	0.2		2	Veth Quote							1.	0.2	0.2						
P2-5	End 2 Propulsion Motor Space Heater	208	1		1.	1.	0.2	0.2	1.		0.2	0.2		2	Veth Quote							1.	0.2	0.2						
P2-6	Hold Level Receptacles	120	1		30.	1.	3.6	3.6	0.2		0.7	0.7		1	Estimate	0.3	0.2	0.2	0.3	0.2	0.2	0.	0.	0.	0.3	0.2	0.2	1.	0.7	0.7
P2-7	Hold Deck 24VDC System/UPS	120	1		19.6	1.	2.4	2.4		0.95	2.5	1.0		(N/A)	N/A		1.2	1.2		1.2	1.2		1.2	1.2		1.2	1.2		1.2	1.2
P2-8	Drive Room 2 Exhaust Fan (510-02)	120	1		0.2	0.8	0.02	0.02	1.		0.0	0.0		1	HVAC Dwg	1.	0.	0.	1.	0.	0.	1.	0.	0.	1.	0.	0.	1.	0.	0.
P2-9	Void 1 Exhaust Fan (510-02)	120	1		0.2	0.8	0.0	0.0	1.		0.0	0.0		1	HVAC Dwg	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02
P2-10	Void 2 Exhaust Fan (510-04)	120	1		0.6	0.8	0.1	0.1	1.		0.1	0.1		1	HVAC Dwg	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.1	0.1
P2-11	Void 3 & Battery Room 2 Exhaust Fan (510-05)	120	1		3.	0.8	0.3	0.4	1.		0.3	0.4		1	HVAC Dwg	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.3	0.4
P2-12	Void 4 Exhaust Fan (510-04)	120	1		0.6	0.8	0.1	0.1	1.		0.1	0.1		1	HVAC Dwg	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.1	0.1
P2-13	Void 5 Exhaust Fan (510-02)	120	1		0.2	0.8	0.0	0.0	1.		0.0	0.0		1	HVAC Dwg	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02
P2-14	Fwd Battery Room Exhaust Fan (510-02)	120	1		0.2	0.8	0.0	0.0	1.		0.0	0.0		1	HVAC Dwg	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02
P2-15	Switchboard Room Exhaust Fan (510-05)	120	1		3.	0.8	0.3	0.4	1.		0.3	0.4		1	HVAC Dwg	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.3	0.4
P2-16	Battery Room 1 Exhaust Fan (510-06)	120	1		0.6	0.8	0.06	0.07	1.		0.1	0.1	Used only in emergency	1	HVAC Dwg													1.	0.06	0.07
P2-17	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																		
P2-18	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																		
P2-19	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																		
P2-20	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																		
Totals							21	21			11	10					2	2		5	5		7	7		2	2		10	10

Guemes Island Ferry Replacement Electrical Power Load Analysis	FILE:	17097.02	BY:	JMG
	REVISION:	P0	CHECKED:	JMR
	DATE:	9/23/2020	APPROVED:	MSM
	DOCUMENT:	17097.02-300-01		

PANEL:	P4 - Main Dk 208-120 Panel	FED FROM:	2S-11
LOCATION:	Switchboard Room	FEEDER CABLE:	2C-14 AWG

Circuit No.	Load Description	V	Φ	HP	FLA	Power Factor	Connected		UF	Eff.	Utilized		Load Notes	Rev.	Load Confidence	Load Data Source	LOAD PROFILES														
							ekW	kVA			Transit - Summer						Transit - Winter			Shore Power (Moored)			No Charging			Emergency					
											DF	ekW					kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA		
P4-1	Crew Day Room Heater (510-13)	208	1		11.1	1.	2.3	2.3	1.		2.3	2.3			3	HVAC Dwg	0.	0.	0.	0.5	1.2	1.2	0.7	1.6	1.6	0.	0.	0.	1.	2.3	2.3
P4-2	Passenger Lounge Heater (510-13)	208	1		11.1	1.	2.3	2.3	1.		2.3	2.3			3	HVAC Dwg	0.	0.	0.	0.5	1.2	1.2	0.7	1.6	1.6	0.	0.	0.	1.	2.3	2.3
P4-3	Passenger Lounge Heater (510-13)	208	1		11.1	1.	2.3	2.3	1.		2.3	2.3			3	HVAC Dwg	0.	0.	0.	0.5	1.2	1.2	0.7	1.6	1.6	0.	0.	0.	1.	2.3	2.3
P4-4	Passenger Lounge Heater (510-13)	208	1		11.1	1.	2.3	2.3	1.		2.3	2.3			3	HVAC Dwg	0.	0.	0.	0.5	1.2	1.2	0.7	1.6	1.6	0.	0.	0.	1.	2.3	2.3
P4-5	Passenger Lounge Exhaust Fan (510-02)	120	1		0.2	0.8	0.	0.	1.		0.02	0.02			3	HVAC Dwg	1.	0.	0.	1.	0.	0.	1.	0.	0.	1.	0.	0.	1.	0.	0.
P4-6	Crew Day Room Receptacles	120	1		30.	1.	3.6	3.6	0.2		0.7	0.7			1	Estimate	0.3	0.2	0.2	0.3	0.2	0.2	0.	0.	0.	0.3	0.2	0.2	1.	0.7	0.7
P4-7	Passenger Lounge Receptacles	120	1		30.	1.	3.6	3.6	0.2		0.7	0.7			1	Estimate	0.3	0.2	0.2	0.3	0.2	0.2	0.	0.	0.	0.3	0.2	0.2	1.	0.7	0.7
P4-8	Upper deck lights interior lights	120	1		2.	1.	0.2	0.2	1.		0.24	0.24			1	Estimate	1.	0.24	0.24	1.	0.24	0.24	0.3	0.07	0.07	1.	0.24	0.24	1.	0.24	0.24
P4-9	Exterior flood lights	120	1		2.	1.	0.2	0.2	1.		0.2	0.2			1	Estimate	1.	0.2	0.2	1.	0.2	0.2	0.3	0.1	0.1	1.	0.2	0.2	1.	0.2	0.2
P4-10	Main deck interior lights	120	1		2.	1.	0.2	0.2	1.		0.2	0.2			1	Estimate	1.	0.2	0.2	1.	0.2	0.2	0.3	0.1	0.1	1.	0.2	0.2	1.	0.2	0.2
P4-11	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																			
P4-12	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																			
P4-13	Spare	120	1		15.	1.	1.8	1.8			0.00	0.00																			
Totals							23	23			11	11					1	1		6	6		7	7		1	1		11	11	

Guemes Island Ferry Replacement Electrical Power Load Analysis	FILE: 17097.02	BY: JMG
	REVISION: P0	CHECKED: JMR
	DATE: 9/23/2020	APPROVED: MSM
	DOCUMENT: 17097.02-300-01	

PANEL: D1 (24VDC Pilothouse Power)	FED FROM: P1-16
LOCATION: Upper Deck	FEEDER CABLE: 2C-10 AWG

LOAD DATA														LOAD DATA INFORMATION			LOAD PROFILES																														
Circuit No.	Load Description	V	Φ	HP	FLA	Power Factor	Connected		UF	Eff.	Utilized		Load Notes	Rev.	Load Confidence	Load Data Source	Transit - Summer			Transit - Winter			Shore Power (Moored)			No Charging			Emergency																		
							ekW	kVA			ekW	kVA					DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA																
D1-1	Feeder from UPS	24	1		100	1.	2.40	2.40			-	-			2	This Sheet																															
D1-2	Backup Feed from D2	24	1		50	1.	1.20	1.20			-	-			2	This Sheet																															
D1-3	Compass Light	24	1		1.	1.	0.02	0.02	1.		0.0	0.0			1	Prelim	1.	0.02	0.02	1.	0.02	0.02	0.1	0.	0.	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02				
D1-4	Pilothouse Display Monitor No. 1	24	1		3.6	1.	0.09	0.09	1.		0.1	0.1			1	Prelim	1.	0.09	0.09	1.	0.09	0.09	0.1	0.01	0.01	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09				
D1-5	Pilothouse Display Monitor No. 2	24	1		3.6	1.	0.09	0.09	1.		0.1	0.1			1	Prelim	1.	0.09	0.09	1.	0.09	0.09	0.1	0.01	0.01	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09				
D1-6	Navigation Lights	24	1		1.7	1.	0.04	0.04	1.		0.0	0.0			1	Prelim	1.	0.04	0.04	1.	0.04	0.04	0.1	0.	0.	1.	0.04	0.04	1.	0.04	0.04	1.	0.04	0.04	1.	0.04	0.04	1.	0.04	0.04	1.	0.04	0.04				
D1-7	Satellite Compass	24	1		0.5	1.	0.01	0.01	1.		0.0	0.0			1	Prelim	1.	0.01	0.01	1.	0.01	0.01	0.1	0.	0.	1.	0.01	0.01	1.	0.01	0.01	1.	0.01	0.01	1.	0.01	0.01	1.	0.01	0.01	1.	0.01	0.01				
D1-8	Navnet Black Box	24	1		5.4	1.	0.13	0.13	1.		0.1	0.1			1	Prelim	1.	0.13	0.13	1.	0.13	0.13	0.1	0.01	0.01	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13				
D1-9	AIS	24	1		3.3	1.	0.08	0.08	1.		0.1	0.1			1	Prelim	1.	0.08	0.08	1.	0.08	0.08	0.1	0.01	0.01	1.	0.08	0.08	1.	0.08	0.08	1.	0.08	0.08	1.	0.08	0.08	1.	0.08	0.08	1.	0.08	0.08				
D1-10	Weather System	24	1		1.	1.	0.02	0.02	1.		0.0	0.0			1	Prelim	1.	0.02	0.02	1.	0.02	0.02	0.1	0.	0.	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02				
D1-11	Fire Detection System	24	1		1.	1.	0.02	0.02	1.		0.0	0.0			1	Prelim	1.	0.02	0.02	1.	0.02	0.02	0.1	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02				
D1-12	Alarm And Monitoring System	24	1		4.	1.	0.10	0.10	1.		0.1	0.1			1	Prelim	1.	0.1	0.1	1.	0.1	0.1	0.1	0.1	0.1	1.	0.1	0.1	1.	0.1	0.1	1.	0.1	0.1	1.	0.1	0.1	1.	0.1	0.1	1.	0.1	0.1				
D1-13	General Alarm And Public Address System	24	1		5.4	1.	0.13	0.13	1.		0.1	0.1			1	Prelim	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13	1.	0.13	0.13				
D1-14	Ship's Whistle Solenoid Valve	24	1		1.	1.	0.02	0.02	1.		0.0	0.0			1	Prelim	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02				
D1-15	Radar	24	1		12.	1.	0.29	0.29	1.		0.3	0.3			1	Prelim	1.	0.29	0.29	1.	0.29	0.29	1.	0.29	0.29	1.	0.29	0.29	1.	0.29	0.29	1.	0.29	0.29	1.	0.29	0.29	1.	0.29	0.29	1.	0.29	0.29				
D1-16	Engine And Ventilation Shutdown System	24	1		1.	1.	0.02	0.02	1.		0.0	0.0			1	Prelim	1.	0.02	0.02	1.	0.02	0.02	0.1	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02				
D1-17	Magnetic Compass	12	1		0.01	1.	0.	0.	1.		0.0	0.0			1	Prelim	1.	0.	0.	1.	0.	0.	1.	0.	0.	1.	0.	0.	1.	0.	0.	1.	0.	0.	1.	0.	0.	1.	0.	0.							
D1-18	Loud Hailer	12	1		2.6	1.	0.03	0.03	1.		0.0	0.0			1	Prelim	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03				
D1-19	VHF Radios No. 1	12	1		2.6	1.	0.03	0.03	1.		0.0	0.0			1	Prelim	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03				
D1-20	VHF Radios No. 2	12	1		2.6	1.	0.03	0.03	1.		0.0	0.0			1	Prelim	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03	1.	0.03	0.03				
D1-21	Spare	24	1		5.0	1.	0.12	0.12																																							
D1-22	Backup supply to D2	24	1		50	1.	1.20	1.20	1.		1.20	1.20			2	D2 EPLA																															
D1-23	Spare	24	1		5.0	1.	0.12	0.12																																							
D1-24	Spare	24	1		5.0	1.	0.12	0.12																																							
		Totals				2.7		2.7				2.4		2.4				1.2			1.2			0.7			0.7			1.2			1.2			1.2			1.2								

Guemes Island Ferry Replacement Electrical Power Load Analysis	FILE:	17097.02	BY:	JMG
	REVISION:	P0	CHECKED:	JMR
	DATE:	9/23/2020	APPROVED:	MSM
	DOCUMENT:	17097.02-300-01		

PANEL: D2 (24VDC Hold Deck Power)	FED FROM: P2-7
LOCATION: Switchboard Room	FEEDER CABLE: 2C-12 AWG

Circuit No.	Load Description	LOAD DATA											LOAD DATA INFORMATION			LOAD PROFILES																			
		V	Φ	HP	FLA	Power Factor	Connected		UF	Eff.	Utilized		Load Notes	Rev.	Load Confidence	Load Data Source	Transit - Summer			Transit - Winter			Shore Power (Moored)			No Charging			Emergency						
		ekW	kVA	ekW	kVA	DF	ekW	kVA			DF	ekW					kVA	DF	ekW	kVA	DF	ekW	kVA	DF	ekW	kVA									
D2-1	Feeder from UPS	24	1		100.	1.	2.4	2.4			-	-			2	This Sheet																			
D2-2	Backup Feed from D1	24	1		50.	1.	1.2	1.2			-	-			2	This Sheet																			
D2-3	Aux Gen Battery Charger	24	1		1.	1.	0.02	0.02	1.		0.02	0.02			1	Prelim	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	1.	0.02	0.02	
D2-4	BMS #1	24	1		3.6	1.	0.09	0.09	1.		0.09	0.09			1	Prelim	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	
D2-5	BMS #2	24	1		3.6	1.	0.09	0.09	1.		0.09	0.09			1	Prelim	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	1.	0.09	0.09	
D2-6	Propulsion Control/Power Managementequipment	24	1		40.0	1.	1.0	1.0	1.		0.96	0.96			1	Estimate	1.	0.96	0.96	1.	0.96	0.96	1.	0.96	0.96	1.	0.96	0.96	1.	0.96	0.96	1.	0.96	0.96	
D2-7	Backup supply to D1	24	1		50.	1.	1.2	1.2	1.		1.20	1.20			2	D2 EPLA																			
D2-8	Spare	24	1		5	1.	0.12	0.12																											
D2-9	Spare	24	1		5	1.	0.12	0.12																											
D2-10	Spare	24	1		5	1.	0.12	0.12																											
D2-11	Spare	24	1		5	1.	0.12	0.12																											
D2-12	Spare	24	1		5	1.	0.12	0.12																											
Totals							3.0	3.0			2.4	2.4						1.16	1.16		1.16	1.16		1.16	1.16		1.16	1.16		1.16	1.16		1.16	1.16	