

Questions and Answers for: Britt Slough Pump Purchase and Installation

Estimated Cost: \$50,000 - \$70,000

Bid Opening: Monday, July 13, 2015 Time: 2:00 p.m. Project Manager: Dianne Crane, Engineering Technician III

#	Questions:	Answers:
1	<p>RFI on the testing portion of the spec., page 20 of 21, section 3.2, E “Water used for flushing and testing or cleaning shall not enter into the existing system.”</p> <p><i>Q; Is this referencing any materials’ left in the pump from factory testing and not the service test?</i></p>	<p>Any required factory flushing and cleaning shall be done prior to installation. Discharge from service test at start up is allowed in system.</p>
2		
3		
4		
5		