

July 13, 2021

ADDENDUM #1

Skagit County
Skagit County Commissioners Building Re-Roof Project

From: Owner

To: All Plan Holders and Plan Centers, as listed in the advertisement for bid

Addendum #1 forms a part of the contract Document and modifies the original bidding documents. This addendum is issued to clarify, add to, or delete from the original documents package.

ADDENDUM ITEMS

Specifications

Item 1. Section 07 54 19 PVC Membrane Roofing under 2.1 Manufacturer item B. Acceptable Manufacturer's **add** 4. Carlisle SynTex Sure-Flex 90 **as an approved manufacturer.**

General Items

- Contractor will be allowed to block off stalls and create a temporary laydown area on the east backside of the building for security fencing, storage of materials, and dumpster locations.
- Contractor will be allowed to temporarily block off with visqueen the air intakes into the HVAC equipment to allow for removal of asbestos. This will need to be coordinated with the owner as the building will be occupied during construction.

PRE BID Walk Thru Attendance

- SEE attached pre bid walk through attendance list.

END OF ADDENDUM #1

Total 2 pages including attachments